

# Emission Test Certificate

Wednesday December 12<sup>th</sup>, 2007

Supplier: Armstrong World Industries Pty Ltd (99 Derby Street, Silver Water NSW 2128)

Sample Description: Armstrong RH99 Fine Fissured Square Edge Ceiling Panel

Date Tested: November 2007

Test Method: GREENGUARD Certification Program for Low Emitting Products incorporating  
ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber  
Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

GREENGUARD Certification Program Emission Criteria for Ceiling Systems	Armstrong RH99 Fine Fissured
Formaldehyde $\leq 0.06 \text{ mg/m}^3$	0.03 $\text{mg/m}^3$
Total Volatile Organic Compounds $\leq 0.5 \text{ mg/m}^3$	0.05 $\text{mg/m}^3$  Individual VOCs were all less than one tenth of their Threshold Limit Value. Carcinogens and reproductive toxins were not identified as part of the VOCs.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Project CV071105